



**EC-TYPE EXAMINATION CERTIFICATE**

Equipment intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

Certificate Number: SIRA99ATEX2136X

Equipment: TX913x Trip Amplifiers

Applicant: Trolex Limited

Address: Newby Road  
Hazel Grove  
Stockport  
Cheshire  
SK7 5DY

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

Sira Certification Service, notified body number 0518 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report number R52X6308A.

Compliance with the Essential Health and Safety Requirements, with exception to those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 50014:1997 (amendments A1-A2)

EN 50020:1994 (amendment A1)

If the sign 'X' is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

Project Number 52X6308A  
Date 2 December 1999  
C. Index 12

M D Shearman  
Certification Manager

*This certificate and its schedules may only be reproduced in its entirety and without change*

**Sira Certification Service**

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk



EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEX2136X

- 11 This EC-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.
- 12 The marking of the equipment shall include the following:



I M1  
EEx ia I (T<sub>a</sub> = -20°C to +70°C)

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

**Sira Certification Service**

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk

Page 2 of 9



**SCHEDULE**

**EC-TYPE EXAMINATION CERTIFICATE NUMBER**

SIRA99ATEX2136X

13

**DESCRIPTION OF EQUIPMENT**

The TX913x Programmable Trip Amplifiers are intended to accept signals from a range of external sensors (e.g. 4-20 mA signals, 0.4-2 V signals, temperature sensors, flammable gas sensors, accelerometers, etc.)

The TX913x Trip Amplifiers are housed in an ABS enclosure and contain a standard Control PCB that is connected to one of a range of I/O PCBs depending on the application. The different versions of the Trip Amplifiers listed below each contain the control PCB connected to a different I/O PCB:

TX9131 4-20 mA Input Trip Amplifiers  
TX9132 Voltage Input Trip Amplifiers  
TX9133 Thermocouple Input Trip Amplifiers  
TX9134 PT100 Temperature Sensor Input Trip Amplifiers  
TX9135 Semiconductor Temperature Sensor Input Trip Amplifiers  
TX9136 Bridge Input Trip Amplifiers  
TX9137 A.C. (Peak) Input Trip Amplifiers  
TX9137 A.C. (RMS) Input Trip Amplifiers  
TX9139 Interposing Relay Trip Amplifier

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

Apart from the TX9139, each version of the Trip Amplifier has 4 variants:

Dual relay output  
4-20 mA output  
0.4-2 V output  
5-15 Hz output

The Control PCB remains the same for all versions and contains a micro-controller, EPROM and EEPROM memories, other logic circuits and an alpha-numeric LCD module, which is mounted directly onto the PCB. A keypad is fitted to the front panel of the Trip Amplifier and is connected to the Control PCB via a flexible ribbon cable.

The I/O PCBs contain some common circuitry as well as circuitry specific to the application. Some versions are based on the same artwork but with different builds to achieve the desired configuration; other versions use different artwork and builds. The safety description of the equipment is shown overleaf.

Date            2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

**Sira Certification Service**

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk



## SCHEDULE

EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEX2136X

### Terminals T1-T8, T11-T12

#### TX9131/2/5

| <b>T1-T4<br/>(sensor)</b> | <b>T5-T6<br/>(supply)</b> | <b>T7-T8<br/>(relay)</b> | <b>T11-T12<br/>(relay reset/power on delay)</b> |
|---------------------------|---------------------------|--------------------------|---|
| $U_o = 16.5 \text{ V}$    | $U_i = 16.5 \text{ V}$    | $U_o = 0$                | $U_o = 16.5 \text{ V}$                          |
| $C_i = 3.6 \text{ nF}$    | $C_i = 3.6 \text{ nF}$    | $U_i = 20 \text{ V}$     | $U_i = 0$                                       |
| $L_i = 0$                 | $L_i = 0$                 | $C_i = 0$                | $C_i = 0$                                       |
|                           |                           | $L_i = 0$                | $L_i = 0$                                       |

Note: terminals T1 and T2 are connected directly to the supply terminals T5-6, so have the same output parameters as the mining power supply.

#### TX9133

| <b>T1-T4<br/>(sensor)</b> | <b>T5-T6<br/>(supply)</b> | <b>T7-T8<br/>(relay)</b> | <b>T11-T12<br/>(relay reset/power on delay)</b> |
|---------------------------|---------------------------|--------------------------|---|
| $U_o = 16.5 \text{ V}$    | $U_i = 16.5 \text{ V}$    | $U_o = 0$                | $U_o = 16.5 \text{ V}$                          |
| $C_i = 2.4 \text{ nF}$    | $C_i = 2.4 \text{ nF}$    | $U_i = 20 \text{ V}$     | $U_i = 0$                                       |
| $L_i = 0$                 | $L_i = 0$                 | $C_i = 0$                | $C_i = 0$                                       |
|                           |                           | $L_i = 0$                | $L_i = 0$                                       |

Note: terminals T1 and T2 are connected directly to the supply terminals T5-6, so have the same output parameters as the mining power supply.

#### TX9134

| <b>T1-T4<br/>(sensor)</b>                  | <b>T5-T6<br/>(supply)</b> | <b>T7-T8<br/>(relay)</b> | <b>T11-T12<br/>(relay reset/power on delay)</b> |
|--|---------------------------|--------------------------|---|
| $U_o = 16.5 \text{ V}$                     | $U_i = 16.5 \text{ V}$    | $U_o = 0$                | $U_o = 16.5 \text{ V}$                          |
| $I_o = 1.163 \text{ A}$                    | $C_i = 1.2 \text{ nF}$    | $U_i = 20 \text{ V}$     | $U_i = 0$                                       |
| $P_o = 1.75 \text{ W}$                     | $L_i = 0$                 | $C_i = 0$                | $C_i = 0$                                       |
| $C_o = 80 \text{ nF}$                      |                           | $L_i = 0$                | $L_i = 0$                                       |
| $L_o/R_o = 52 \text{ } \mu\text{H}/\Omega$ |                           |                          |   |
| $C_i = 3.6 \text{ nF}$                     |                           |                          |   |
| $L_i = 0$                                  |                           |                          |   |

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

### Sira Certification Service



## SCHEDULE

EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEX2136X

### TX9136

| T1-T4<br>(sensor)                 | T5-T6<br>(supply)                 | T7-T8<br>(relay)     | T11-T12<br>(relay reset/power on delay)   |
|-----------------------------------|-----------------------------------|----------------------|---|
| $U_o = 16.5 \text{ V}$            | $U_i = 16.5 \text{ V}$            | $U_o = 0$            | $U_o = 16.5 \text{ V}$                    |
| $I_o = 1.163 \text{ A}$           | $C_i = 1.2 \text{ nF}$            | $U_i = 20 \text{ V}$ | $C_o = 12 \text{ }\mu\text{F}$            |
| $C_o = 300 \text{ nF}$            | $L_i = 245 \text{ }\mu\text{H} *$ | $C_i = 0$            | $L_o/R_o = 52 \text{ }\mu\text{H}/\Omega$ |
| $L_o = 80 \text{ }\mu\text{H}$    |                                   | $L_i = 0$            | $U_i = 0$                                 |
| $C_i = 12.48 \text{ }\mu\text{F}$ |                                   |                      | $C_i = 0$                                 |
| $L_i = 165 \text{ }\mu\text{H}$   |                                   |                      | $L_i = 0$                                 |

\* Note: the internal inductance is in series with a resistance of at least  $14.25 \Omega$ . This is inductively non-incendive when the apparatus is used in conjunction with a power supply having a peak output voltage ( $U_o$ ) not exceeding  $16.5 \text{ V}$ .

### TX9137

| T1-T4<br>(sensor)                         | T5-T6<br>(supply)      | T7-T8<br>(relay)     | T11-T12<br>(relay reset/power on delay) |
|---|------------------------|----------------------|---|
| $U_o = 16.5 \text{ V}$                    | $U_i = 16.5 \text{ V}$ | $U_o = 0$            | $U_o = 16.5 \text{ V}$                  |
| $I_o = 183 \text{ mA}$                    | $C_i = 1.2 \text{ nF}$ | $U_i = 20 \text{ V}$ | $U_i = 0$                               |
| $P_o = 752 \text{ mW}$                    | $L_i = 0$              | $C_i = 0$            | $C_i = 0$                               |
| $C_o = 80 \text{ nF}$                     |                        | $L_i = 0$            | $L_i = 0$                               |
| $L_o/R_o = 52 \text{ }\mu\text{H}/\Omega$ |                        |                      |   |
| $C_i = 1.2 \text{ nF}$                    |                        |                      |   |
| $L_i = 0$                                 |                        |                      |   |

### TX9139

| T4 & T6<br>(signal)                          | T5-T6<br>(supply)      | T1-T3, T7-T12<br>(relay) |
|--|------------------------|--------------------------|
| $U_o = 16.5 \text{ V}$                       | $U_i = 16.5 \text{ V}$ | $U_o = 0$                |
| $I_o = 8 \text{ mA}$                         | $C_i = 1.2 \text{ nF}$ | $U_i = 20 \text{ V}$     |
| $P_o = 33 \text{ mW}$                        | $L_i = 0$              | $C_i = 0$                |
| $C_o = 11 \text{ }\mu\text{F}$               |                        | $L_i = 0$                |
| $L_o/R_o \leq 52 \text{ }\mu\text{H}/\Omega$ |                        |                          |
| $C_i = 0$                                    |                        |                          |
| $L_i = 0$                                    |                        |                          |

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

**Sira Certification Service**



## SCHEDULE

EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEX2136X

### Terminals T9-T10 (excluding the TX9139)

The parameters depend on the variant as follows:

| Dual relay           | 4-20 mA                | 0.4-2 V                | 5-15 Hz               |
|----------------------|------------------------|------------------------|-----------------------|
| $U_o = 0$            | $U_o = 16.5 \text{ V}$ | $U_o = 16.5 \text{ V}$ | $U_o = 0$             |
| $U_i = 20 \text{ V}$ | $C_i = 0$              | $C_i = 0$              | $U_i = 20 \text{ V}$  |
| $C_i = 0$            | $L_i = 0$              | $L_i = 0$              | $P_i = 2.5 \text{ W}$ |
| $L_i = 0$            |                        |                        | $C_i = 0$             |
|                      |                        |                        | $L_i = 0$             |

## 14 DESCRIPTIVE DOCUMENTS

### 14.1 DRAWINGS

#### 14.1.1 All versions

| Drawing No. | Rev.   | Sheet | Date      | Title   |
|-------------|--------|-------|-----------|---|
| P5093.27    | 1 of 1 | C     | 21 Jan 97 | Reed Relay  |
| P5460.01    | 1 of 1 | A     | 07 Jul 97 | Circuit Diagram Control P.C.B.                                  |
| P5460.07    | 1 of 2 | B     | 25 Feb 99 | General Assembly  |
| P5460.07    | 2 of 2 | B     | 25 Feb 99 | General Arrangement of Enclosure                                |
| P5460.45    | 1 of 1 | A     | 21 Jan 98 | Interconnection Block Diagram                                   |
| P5460.109   | 1 of 1 | A     | 18 May 98 | Circuit Diagram 5-15 Hz ModulebP.C.B.                           |
| P5460.111   | 1 of 1 | A     | 25 Sep 98 | Circuit Diagram Modifications for 5-15 Hz Modules Output P.C.B. |
| P5460.127   | 1 of 1 | A     | 25 Nov 99 | Label Details   |

#### 14.1.2 TX9131/2/5

| Drawing No. | Rev.   | Sheet | Date      | Title   |
|-------------|--------|-------|-----------|---|
| P5460.29    | 1 to 7 | A     | 09 Jan 98 | Output PCB  |
| P5460.38    | 1 to 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (V, I, KTY81 Input) |

#### 14.1.3 TX9133

| Drawing No. | Rev.   | Sheet | Date      | Title  |
|-------------|--------|-------|-----------|--|
| P5460.40    | 1 to 7 | A     | 09 Jan 98 | Output PCB   |
| P5460.100   | 1 to 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (Thermocouple Input) |

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

### Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk



## SCHEDULE

EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEN2136X

14.1.4 **TX9134**

| Drawing No. | Rev.   | Sheet | Date      | Title                                       |
|-------------|--------|-------|-----------|---|
| P5460.41    | 1 to 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (PT100 Input) |
| P5460.82    | 1 to 7 | A     | 09 Jan 98 | Output PCB                                  |

14.1.5 **TX9136**

| Drawing No. | Rev.   | Sheet | Date      | Title  |
|-------------|--------|-------|-----------|--|
| P5460.28    | 1 to 7 | A     | 09 Jan 98 | Output PCB                                   |
| P5460.37    | 1 to 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (Bridge Input) |

14.1.6 **TX9137 (RMS)**

| Drawing No. | Rev.   | Sheet | Date      | Title  |
|-------------|--------|-------|-----------|--|
| P5460.02    | 1 of 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (A.C. RMS Input) |
| P5460.02    | 2 of 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (A.C. RMS Input) |
| P5460.02    | 3 of 3 | B     | 26 Nov 99 | Circuit Diagram Output P.C.B. (A.C. RMS Input) |
| P5460.5     | 1 to 7 | A     | 09 Jan 98 | Output PCB                                     |

14.1.7 **TX9137 (PEAK)**

| Drawing No. | Rev.   | Sheet | Date      | Title   |
|-------------|--------|-------|-----------|---|
| P5460.23    | 1 to 7 | A     | 09 Jan 98 | Output PCB                                      |
| P5460.26    | 1 to 3 | A     | 09 Jan 98 | Circuit Diagram Output P.C.B. (A.C. Peak Input) |

14.1.8 **TX9139**

| Drawing No. | Rev.           | Sheet | Date      | Title                     |
|-------------|----------------|-------|-----------|---------------------------|
| P5460.113   | 1 to 4<br>of 5 | A     | 25 Feb 99 | Output PCB                |
| P5460.114   | 1 of 1         | A     | 26 Feb 99 | Certified Circuit Diagram |

14.2 Report No. R52X6308A.

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

### Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk



**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

**sira**  
Certification Service

## SCHEDULE

EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEX2136X

15 **SPECIAL CONDITIONS FOR SAFE USE** (*denoted by X after the certificate number*)

- 15.1 The TX913x Trip Amplifiers shall be installed in an outer enclosure that provides an ingress protection of at least IP54 to EN 60529:1991. Metallic enclosures shall also comply with clause 8.1 of EN 50014:1997.

The outer enclosure shall be marked in a visible, external location with an additional label that displays at least the following information:

Contains Trolex TX913x Programmable Trip Amplifiers  
EEx ia I (T<sub>a</sub> = -20°C to +70°C)  
SIRA99ATEX2136X

If the enclosure is manufactured from plastics or incorporates a plastics component with a surface area in excess of 100 cm<sup>2</sup>, then it shall also be marked with a static warning label:

“STATIC HAZARD! DO NOT RUB WITH A DRY CLOTH”

- 15.3 If the outer enclosure has a carries a static warning label, then it shall not be installed in a location where it is likely to be subjected to conditions that may induce static charges, e.g. high velocity dust laden air.
- 15.4 This certificate only relates to the TX913x Trip Amplifiers and does not cover the function of any other electrical apparatus installed in the outer enclosure.
- 15.5 The internal temperature of this apparatus may rise above 150°C under normal or fault conditions; therefore, care shall be taken when the enclosure is opened to ensure that no dust enters the apparatus.

16 **ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSR'S)**

The table below lists all relevant EHSR's not addressed by the standards listed in this certificate. These EHSR's have been assessed in Report No. R52X6308A.

| Annex II<br>Clause Number | Title   |
|---------------------------|---|
| 1.2.4                     | Dust deposits                                 |
| 1.2.5                     | Additional means of protection                |
| 1.4.1                     | Safe function in changing external conditions |
| 1.4.2                     | Withstanding attach by aggressive substances  |
| 2.0.1.2                   | Protection against dust ingress               |
| 2.0.1.3                   | Surface temperatures to be below AIT of dust  |

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

**Sira Certification Service**

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk

Page 8 of 9

Sira Certification Service is a service of Sira Test & Certification Ltd





## SCHEDULE

EC-TYPE EXAMINATION CERTIFICATE NUMBER

SIRA99ATEX2136X

### 17 CONDITIONS OF CERTIFICATION

- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of SCS Certificates.
- 17.2 In affixing the Sira certificate number to the apparatus the applicant attests on his own responsibility that the apparatus conforms to the documents listed herein.

If the marked apparatus is found not to comply Sira Certification Service should be notified immediately at its offices at South Hill, Chislehurst, Kent BR7 5EH, England.

- 17.3 This certificate relies on the following previously-certified products. When used as part of the TX913x, the key attributes listed in the table below shall still be maintained by their original certificate.

| Product                         | Certificate number | Key attributes |
|---------------------------------|--------------------|----------------|
| Littelfuse fuse                 | BAS Ex 832302U     | EEx ia IIC     |
| Bedford OPI11264D opto-isolator | BAS Ex 89C2096U/2  | EEx ia IIC     |

- 17.4 It is the manufacturer's responsibility to take all reasonable steps to ensure that the user or installer complies with the requirements detailed in Special Conditions for Safe Use 15.1 and retains evidence to this effect.

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

Date 2 December 1999

*This certificate and its schedules may only be reproduced in its entirety and without change*

### Sira Certification Service



## EC TYPE-EXAMINATION CERTIFICATE VARIATION

**CERTIFICATE NUMBER** Sira 99ATEX2136X **Dated** 2 December 1999

**VARIATION NUMBER** 1 (ONE) **Dated** 16 November 2000

### VARIATION TO EQUIPMENT

To permit:

- 1 The use of pad printing as an alternative method of marking.

### DESCRIPTIVE DOCUMENTS

| Number   | Sheet  | Rev | Date      | Description      |
|----------|--------|-----|-----------|------------------|
| P5460.07 | 1 of 1 | C   | 13 Jun 00 | General Assembly |

### ADDITIONAL CONDITIONS OF CERTIFICATION

None

**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

**File No** 52V6983

**Report No.** NA


  
**R Cooper IEng LInstMC**  
**Deputy Chief Executive**

This Variation and its schedules may only be reproduced in its entirety and without change

**Sira Certification Service**

**Page 1 of 1**

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk



**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

**sira**  
Certification Service

## EC TYPE EXAMINATION CERTIFICATE VARIATION

**CERTIFICATE NUMBER** Sira 99ATEX2136X **Dated** 2 December 1999

**VARIATION NUMBER** 2 (TWO) **Dated** 4 July 2001  
**Re-issued** 15 March 2002

### VARIATION TO EQUIPMENT

To permit:

- 1 The addition of the TX9151 Liquid Flow Trip Amplifier to the existing range of Trip Amplifiers.

#### Description of TX9151

The TX9151 Liquid Flow Trip Amplifier is typically designed to interface with a Liquid Flow Sensor (LFS) via a sensor measuring the differential pressure inside the LFS, this parameter is then used to calculate the flow rate. This gives a voltage output up to 5 V at 10 mA maximum. In conjunction with this, a second sensor measures the line pressure. The Control PCB, which is the same for all Trip Amplifiers, contains a micro-controller, EPROM & EEPROM memories, other logic circuits and an alpha-numeric LCD module that is mounted directly onto the PCB. A keypad is fitted to the front panel of the Trip Amplifier and is connected to the Control PCB via a flexible ribbon cable.

The TX9151 has 5 variants, depending on the output at terminals T9-10:

Dual relay output  
4-20 mA output  
0.4-2 V output – standard  
0.4-2 V output – PD543  
5-15 Hz output

The TX9151 has the following safety description:

#### Terminals T1-T8, T11-T12

| <b>T1 (sensor 1 supply), T2 (sensor 1 signal in) &amp; T6 (zero volts)</b>  | <b>T5 (supply), T4 (sensor 2 signal in) &amp; T3 (zero volts)</b><br>[See note 1]   | <b>T5 (supply) T6 (zero volts)</b>                            | <b>T7-T8 (relay)</b>   | <b>T11 (relay reset) &amp; T6 (zero volts)</b>  | <b>T12 (power on delay) &amp; T6 (zero volts)</b>   |
|---|---|---|--|---|---|
| $U_o = 7.14 \text{ V}$<br>$I_o = 75 \text{ mA}$<br>$P_o = 0.31 \text{ W}$<br>$C_o = 5 \mu\text{F}$<br>$L_o = 100 \mu\text{H}$ | $U_i = 16.5 \text{ V}$<br>$C_i = 1.2 \text{ nF}$<br>$L_i = 0$<br>$U_o = 16.5 \text{ V}$<br>$I_o = 5 \text{ mA}$<br>$P_o = 20 \text{ mW}$<br>$C_o = 120 \text{ nF}$<br>$L_o/R_o = 50 \mu\text{H}/\Omega$ | $U_i = 16.5 \text{ V}$<br>$C_i = 1.2 \text{ nF}$<br>$L_i = 0$ | $U_o = 0$<br>$U_i = 20 \text{ V}$<br>$P_i = 2.3 \text{ W}$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 16.5 \text{ V}$<br>$I_o = 5 \text{ mA}$<br>$P_o = 20 \text{ mW}$<br>$C_o = 120 \text{ nF}$<br>$L_o/R_o = 50 \mu\text{H}/\Omega$<br>$U_i = 0$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 16.5 \text{ V}$<br>$I_o = 5 \text{ mA}$<br>$P_o = 20 \text{ mW}$<br>$C_o = 120 \text{ nF}$<br>$L_o/R_o = 50 \mu\text{H}/\Omega$<br>$U_i = 0$<br>$C_i = 0$<br>$L_i = 0$ |

Note 1: For the purpose of system assessment, it should be noted that cable connected to terminal T5 from the supply also feeds sensor 2 (typically a line pressure sensor).

This Variation and its schedules may only be reproduced in its entirety and without change

### Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk

Sira Certification Service is a service of Sira Test & Certification Ltd



**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

**sira**  
Certification Service

## EC TYPE EXAMINATION CERTIFICATE VARIATION

**CERTIFICATE NUMBER** Sira 99ATEX2136X **Dated** 2 December 1999

**VARIATION NUMBER** 2 (TWO) **Dated** 4 July 2001  
**Re-issued** 15 March 2002

**Terminals T9/T10:** the parameters depend on the variant as follows:

| Dual relay<br>(TX9151.31)  | 4-20 mA<br>(TX9151.32)   | 0.4-2 V<br>(TX9151.33)<br>[standard version]  | 0.4-2 V<br>(TX9151.33.PD543)  | 5-15 Hz<br>(TX9151.34)   |
|--|--|---|---|--|
| $U_o = 0$<br>$U_i = 20\text{ V}$<br>$P_i = 2.3\text{ W}$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 16.5\text{ V}$<br>$I_o = 472\text{ mA}$<br>$P_o = 1.95\text{ W}$<br>$C_o = 120\text{ nF}$<br>$L_o/R_o = 50\mu\text{H}/\Omega$ | $U_o = 16.5\text{ V}$<br>$I_o = 50\text{ mA}$<br>$P_o = 0.21\text{ W}$<br>$C_o = 120\text{ nF}$<br>$L_o/R_o = 50\mu\text{H}/\Omega$ | $U_o = 7.14\text{ V}$<br>$I_o = 50\text{ mA}$<br>$P_o = 0.21\text{ W}$<br>$C_o = 56\mu\text{F}$<br>$L_o/R_o = 20\mu\text{H}/\Omega$ | $U_o = 0$<br>$U_i = 20\text{ V}$<br>$P_i = 2.5\text{ W}$<br>$C_i = 0$<br>$L_i = 0$ |

### DESCRIPTIVE DOCUMENTS

| Drawing no. | Sheets | Rev. | Date      | Description  |
|-------------|--------|------|-----------|--|
| P5460.07    | 1 of 1 | C    | 13 Jun 00 | General Assembly   |
| P5514.01    | 1 to 3 | B    | 04 Feb 02 | Certified Circuit Diagram Output PCB (Flow Sensor Input) |
| P5514.03    | 1 of 1 | B    | 04 Feb 02 | Output PCB, Flow Sensor Input [artwork]                  |

### ADDITIONAL CONDITIONS OF CERTIFICATION

None

Re-issued 15 March 2002

To correct the safety parameters applicable to terminals T9/T10 and incorporate a modified output PCB circuit.

**File No.** 52A6519 and 52A8478

**M D Shearman**  
**Certification Manager**

**Report No.** R52A6519A and R52A8478A

This Variation and its schedules may only be reproduced in its entirety and without change

### Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk

Sira Certification Service is a service of Sira Test & Certification Ltd



**UNCONTROLLED DOCUMENT**  
**This document is not subject**  
**to amendments**

**sira**  
Certification Service

## EC TYPE EXAMINATION CERTIFICATE VARIATION

**CERTIFICATE NUMBER** Sira 99ATEX2136X **Dated** 2 December 1999

**VARIATION NUMBER** 3 (THREE) **Dated** 5 March 2002

### VARIATION TO EQUIPMENT

To permit:

- 1 The correction and clarification of the parts lists and general arrangement drawings.
- 2 The removal of the input voltage from the marking drawing.
- 3 The name of the equipment to become the TX91xx Series Trip Amplifiers, thereby encompassing the type TX9151.

### DESCRIPTIVE DOCUMENTS

| Drawing no. | Sheets | Rev. | Date      | Description                           |
|-------------|--------|------|-----------|---------------------------------------|
| P5460.07    | 1 of 2 | D    | 20 Feb 02 | All versions: general assembly        |
| P5460.02    | 3 of 3 | C    | 06 Feb 02 | TX9137 (RMS) output board parts list  |
| P5460.26    | 3 of 3 | B    | 06 Feb 02 | TX9137 (Peak) output board parts list |
| P5460.37    | 3 of 3 | B    | 06 Feb 02 | TX9136 output board parts list        |
| P5460.38    | 3 of 3 | B    | 06 Feb 02 | TX9131/2/5 output board parts list    |
| P5460.41    | 3 of 3 | B    | 06 Feb 02 | TX9134 output board parts list        |
| P5460.100   | 3 of 3 | B    | 06 Feb 02 | TX9133 output board parts list        |
| P5460.127   | 1 of 1 | B    | 26 Feb 02 | Label details                         |
| P5514.01    | 3 of 3 | B    | 06 Feb 02 | TX9151 output board parts list        |

### ADDITIONAL CONDITIONS OF CERTIFICATION

None

**File No.** 52A8478

**Report No.** R52A8478A and AX4300

**M D Shearman**  
**Certification Manager**

This Variation and its schedules may only be reproduced in its entirety and without change

### Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@sirac.co.uk

Sira Certification Service is a service of Sira Test & Certification Ltd



**UNCONTROLLED DOCUMENT**  
This document is not subject  
to amendments

**sira**  
Certification Service

## EC TYPE EXAMINATION CERTIFICATE VARIATION

**CERTIFICATE NUMBER** Sira 99ATEX2136X **Dated** 2 December 1999

**VARIATION NUMBER** 4 (FOUR) **Dated** 9 August 2002

### VARIATION TO EQUIPMENT

To permit:

- 1 The specification of a more detailed safety description for the TX9131/2/5:

#### Terminals T1-T8, T11-T12

| <b>T1-T2<br/>(sensor power)</b>                               | <b>T3-4<br/>(sensor signal)</b>  | <b>T5-T6<br/>(supply)</b>                                     | <b>T7-T8<br/>(relay)</b>                                    | <b>T11-T12<br/>(relay reset/power<br/>on delay)</b>           |
|---|--|---|---|---|
| $U_o = 16.5 \text{ V}$<br>$C_i = 2.4 \text{ nF}$<br>$L_i = 0$ | $U_o = 16.5 \text{ V}$<br>$I_o = 33 \text{ mA}$<br>$P_o = 135 \text{ mW}$<br>$C_i = 1.2 \text{ nF}$<br>$L_i = 0$ | $U_i = 16.5 \text{ V}$<br>$C_i = 3.6 \text{ nF}$<br>$L_i = 0$ | $U_o = 0$<br>$U_i = 20 \text{ V}$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 16.5 \text{ V}$<br>$U_i = 0$<br>$C_i = 0$<br>$L_i = 0$ |

Note: terminals T1 and T2 are connected directly to the supply terminals T5-6, so have the same output parameters as the mining power supply.

#### Terminals T9-T10

| <b>Dual relay</b>   | <b>4-20 mA</b>                                   | <b>0.4-2 V</b>                                   | <b>5-15 Hz</b>   |
|---|--|--|--|
| $U_o = 0$<br>$U_i = 20 \text{ V}$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 16.5 \text{ V}$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 16.5 \text{ V}$<br>$C_i = 0$<br>$L_i = 0$ | $U_o = 0$<br>$U_i = 20 \text{ V}$<br>$P_i = 2.5 \text{ W}$<br>$C_i = 0$<br>$L_i = 0$ |

### DESCRIPTIVE DOCUMENTS

None

### ADDITIONAL CONDITIONS OF CERTIFICATION

None

**File No.** 52V9206

**M D Shearman**  
Certification Manager

**Report No.** NA

This Variation and its schedules may only be reproduced in its entirety and without change

### Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England  
Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330  
Email: exhazard@siratc.co.uk

Sira Certification Service is a service of Sira Test & Certification Ltd



**UNCONTROLLED DOCUMENT**  
This document is not subject  
to amendments

**sira**  
Certification Service

## EC TYPE-EXAMINATION CERTIFICATE VARIATION

**CERTIFICATE NUMBER** Sira 99ATEX2136X **Dated** 2 December 1999

**VARIATION NUMBER** 5 (FIVE) **Dated** 14 March 2005

### VARIATION TO EQUIPMENT

To permit:

- 1 The value of the output voltage of any terminal that has a previously designated  $U_o$  of 16.5 V to be equal to the  $U_o$  of the equipment connected to the supply terminals T5-T6 up to a maximum of 16.5 V.

### DESCRIPTIVE DOCUMENTS

None

### ADDITIONAL CONDITIONS OF CERTIFICATION

None

**File No.** 52V13167

**Report No.** R52V13167A

**C Ellaby**  
**Certification Officer**

This Variation and its schedules may only be reproduced in its entirety and without change